

TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.

(TEXTILE TESTING INSTITUTE)

Cejl 480/12, Zábrdovice, 602 00 Brno, Czech Republic Certification body for the certification of products No. 3044 accredited by CAI according to EN ISO/IEC 17065

issues

CERTIFICATE

(TZU) 4500

No. 21 - 004

Manufacturer:

Vescom B.V., Sint Jozefstraat 20, 5753 AV Deurne, Netherland. B.V.

ID: 17084508

Product:

Drapery - Nila + print

Material composition: 100 % polyester FR (100 % acrylic lamination)

Mass per unit area: 275 g.m⁻²

This certificate shows the conformity of the product with the following technical specification:

• EN 13773:2003 Textiles and textile products - Burning behaviour - Curtains and drapes - Classification scheme

Testing according to: EN 1101:1995, EN 13772:2011

It is certified,

that assessed product meets the requirements of the technical standard EN 13773, class 1 regarding the burning behaviour.

The product does not ignite and does not burn in defined conditions.

(Tested as new material, without pre – treatment by washing.)

Certification system: Type testing (certification scheme of TZÚ No. 1/01.04.2020). This Certificate is issued within the scope of accreditation of Certification Body. The base for the Certificate is the Final Protocol No. COV/21/044 from 25.01.2021 issued by Certification Body Textile Testing Institute in Brno. Final Protocol is an inseparable part of the Certificate.

Certificate issued: Brno 10.02.2021

Validity up to: 29.02.2024







Ing. Svatava Horáčková Head of Certification Body