



Date of Issue: 2/21/2020
 Report Number: 20-000798
 Revision Number: 1
 Date Order Received: 02/14/2020

For the Account of: Vescom, B.V.
 Sint Jozestraat 20
 5753 Av Duerne

Client's Identification: Wilson

CERTIFICATE OF TESTING

TEST PERFORMED: Colorfastness to Light AATCC Test Method 16.3-2014, Option 3

TEST RESULTS

Rating	Number of Hours
Class 5.0	40

RATING SYSTEM

- Class 5 No fading or color change
- Class 4 Slight fading or color change
- Class 3 Noticeable fading or color change
- Class 2 Considerable fading or color change
- Class 1 Much fading or color change

NOTES

Light Source: Xenon -Arc, Water Cooled, Continuous Light
Scale Used for Evaluation: AATCC Gray Scale for Color Change

ACCEPTANCE CRITERIA

A.C.T. Standard	Acceptance Criteria
Upholstery	Class 4 minimum - 40 hours
Direct Glue Wallcoverings	Class 4 minimum - 40 hours
Panels and Upholstered Walls	Class 4 minimum - 40 hours
Drapery	Class 4 minimum - 60 hours

CERTIFICATION I certify that the above results were obtained after testing specimen in accordance with the procedures and equipment specified by the standard stated above.

Authorized Signature

Date Order Completed: 02/20/2020