



Date of Issue: 6/28/2022 Report Number: 21-000017

Revision Number:2

Date Order Received: 01/05/2021

For the Account of: Vescom, B.V.
Sint Jozestraat 20
5753 Av Duerne

Client's Identification:	Elara		
Cheffe definition	Liaia		
	Nono		
	None		

CERTIFICATE OF TESTING

TEST PERFORMED: Flame Tests of Flame-Resistant Fabrics and Film CAN/ULC S109-14 folded testing method

TEST RESULTS

Small Flame Test	Specimen	After Flame (s)	Flaming Drip (s)	Char Length (mm)
	1	0.0	0.0	88
	2	0.0	0.0	94
	3	0.0	0.0	79
	4	0.0	0.0	82
	5	0.0	0.0	70
	6	0.0	0.0	74
	7	0.0	0.0	62
	8	0.0	0.0	68
	9	0.0	0.0	60
	10	0.0	0.0	68
	Average	0.0	0.0	75
Large Flame Test	Specimen	After Flame (s)	Flaming Drip (s)	Char Length (mm)
	1	0.0	0	242
	2	0.0	0	255
	3	0.0	0	282
	4	0.0	0	260

Approxi	mate v	weight (oz./sa	. vd	: 109

т	es	tΔ	А٠
	ъэ	re	u.

☑ Initially	☐ After water leaching
☐ After laundering	☐ After scrubbing

☐ After dry cleaning ☐ After accelerated weathering

ACCEPTANCE CRITERIA

Small Flame Test:

- 1. Portions or residue of the material (flaming drip) which break or drip from the test specimens shall not continue to flame for more than seconds on the floor of the test cabinet
- 2. The vertical spread of the flame and afterglow on the material as indicated by the damaged length (char length) shall not exceed:
 - a. Maximum Average Length: 165mm (6.5 inches)
 - b. Maximum Individual Length: 190mm (7.5 inches)

Large Flame Test:

- 1. Portions or residues of the material (flaming drip) which break or drip from the test specimens shall not continue to flame for more that 2 seconds on the floor beneath the test enclosure
- 2. The surface spread of flame shall not exceed 635mm (25 inches) above the tip of the test flame in folded specimens and 250mm (1 inches) in flat specimens.

553 76th Street, Byron Center, MI 49315

P: 616-559-6123 E: testlab@applied-lab.com

Page 1 of 2

CONCLUSION	Based on the above Results and Acceptance Criteria, the item tested : ☑ Complies ☐ Does Not Comply
specified by the sta	certify that the above results were obtained after testing specimen in accordance with the procedures and equipment and address and equipment and address and equipment and accordance with the procedures and accordance with the procedure and accordance with the procedure accordance with the
July Matte Jillian Matic	æ

Authorized Signature

Date Order Completed: 01/06/2021