

## CLASSIFICATION OF REACTION TO FIRE PERFORMANCE IN ACCORDANCE WITH EN 13501-1:2007+A1:2009

Classification no.	2015-Efectis-R000382
Sponsor	Vescom BV P.O. Box 70 5750 AB DEURNE THE NETHERLANDS
Product name	<b>Vescom vinyl wall covering mass approx. 350 g/m<sup>2</sup></b>
Prepared by	Efectis Nederland BV
Notified body no.	1234
Author(s)	C.C.M. Steinhage B.Sc. E.O. van der Laan M.Sc.
Project number	ENL-15-000073
Date of issue	March 2015
Number of pages	5

## 1. INTRODUCTION

---

This classification report defines the classification assigned to **Vescom vinyl wall covering, mass approx. 350 g/m<sup>2</sup>** in accordance with the procedures given in EN 13501-1:2007+A1:2009.

## 2. DETAILS OF CLASSIFIED PRODUCT

---

### 2.1 GENERAL

The product, **Vescom vinyl wall covering, mass approx. 350 g/m<sup>2</sup>**, is defined as a wall covering.

### 2.2 MANUFACTURER

Vescom BV  
P.O. Box 70  
5750 AB DEURNE  
THE NETHERLANDS

### 2.3 PRODUCT DESCRIPTION

According to the sponsor the product is composed of:  
Material: vinyl  
Mass: approx. 350 g/m<sup>2</sup>

## 3. STANDARDS, REPORTS, RESULTS AND CRITERIA IN SUPPORT OF THIS CLASSIFICATION

---

### 3.1 APPLICABLE (PRODUCT) STANDARDS

EN 15102:2007      Decorative wall coverings - Roll and panel form products

### 3.2 REPORTS

Name of Laboratories	Name of sponsor	Report ref. no.	Test method
Efectis Nederland BV THE NETHERLANDS	Vescom BV THE NETHERLANDS	2015-Efectis-R000380 2015-Efectis-R000381	EN ISO 11925-2:2010 EN 13823:2014

### 3.3 TEST RESULTS

Test method and test number	Parameter	No. tests	Results	
			Continuous parameter - mean (m)	Compliance with parameters
<b>EN ISO 11925-2</b>				
surface flame impingement	$F_s \leq 150$ mm	6	53	-
	Ignition of filter paper		-	Compliant
Edge flame impingement	$F_s \leq 150$ mm	6	43	-
	Ignition of filter paper		-	Compliant
<b>EN 13823</b>				
	FIGRA <sub>0,2MJ</sub> [W/s]	3	77	-
	FIGRA <sub>0,4MJ</sub> [W/s]		28	-
	THR <sub>600s</sub> [MJ]		1.4	-
	LFS < edge		-	Compliant
	SMOGRA [m <sup>2</sup> /s <sup>2</sup> ]		41	-
	TSP <sub>600s</sub> [m <sup>2</sup> ]		40	-
	Flaming debris - flaming ≤ 10 s - flaming > 10 s		-	Compliant Compliant

### 3.4 CLASSIFICATION CRITERIA


Fire classification of construction products and building elements Excluding floorings and linear pipe thermal insulation products			
Classification criteria			
Class	B	C	D
EN ISO 11925-2 Exposure = 30 s	$F_s \leq 150$ mm within 60 s Ignition of the paper in EN ISO 11925-2 results in a d2 classification.		
EN 13823	FIGRA <sub>0,2 MJ</sub> ≤ 120 W/s LFS < edge of specimen THR <sub>600s</sub> ≤ 7.5 MJ	FIGRA <sub>0,4 MJ</sub> ≤ 250 W/s LFS < edge of specimen THR <sub>600s</sub> ≤ 15 MJ	FIGRA <sub>0,4 MJ</sub> ≤ 750 W/s
Additional classification			
Smoke production	s1 = SMOGRA ≤ 30 m <sup>2</sup> /s <sup>2</sup> and TSP <sub>600s</sub> ≤ 50 m <sup>2</sup> ; s2 = SMOGRA ≤ 180 m <sup>2</sup> /s <sup>2</sup> and TSP <sub>600s</sub> ≤ 200 m <sup>2</sup> ; s3 = not s1 or s2		
Flaming Droplets/particles	d0 = no flaming droplets/ particles in EN 13823 within 600 s; d1 = no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s; d2 = not d0 or d1.		



## 5. LIMITATIONS

---

This classification document does not represent type approval or certification of the product.



C.C.M. Steinhage B.Sc.  
Project leader reaction to fire



E.O. van der Laan M.Sc.  
Project leader reaction to fire