Lerchenweg 1 D-97650 Fladungen Tel.: int – 49 – 9778-7480-200 hoch.fladungen@t-online.de Hoch

www.reaction-to-fire.de

Test laboratory for the fire behavior of building materials, Dipl.-Ing. (FH) Andreas Hoch Testing, supervising and certifying body, authorized by the building supervision authority

TEST REPORT PZ-Hoch-190357

for the proof of Fire behaviour according to DIN 4102, part 1 Translation of the German test report – no guarantee for translation of technical terms

company	Vescom B.V. St. Jozefstraat 20 NL-5753 Deurne
description of samples	fabric consisting of 100% Polyester FR colour: light grey (glossy)
name of the material	"Tinos" Dessin: 8078
sampling	by the company itself
content of request	Proof of flammability to classify building materials to class B1 "schwerentflammbar" according to DIN 4102, part 1
validity of test report	31.03.2024
result	The examined product meets the requirements of class B1 for "schwerentflammbare" (hardly flammable) building materials according to DIN 4102, part 1 (May 1998), suspended freely or with distance of >40 mm to same or other plain materials.

This test report includes 4 pages and 4 enclosures.

Remark: If the above mentioned building material is not used as product according to MBO § 2, Abs. 9, Ziffer1, there is no need for a general building supervisory test report.

This test report is not valid if the examined building material is used as product in the meaning of state building prescriptions (MBO § 17, Abs. 3).

This test report does not replace an eventually necessary proof of applicability concerning building supervisory or building laws in the meaning of state building prescriptions. This has to be verified by:

- "allgemeine bauaufsichtliche Zulassung" (general building inspectorate approval) or by
- "allgemeines bauaufsichtliches Prüfzeugnis" (general building inspectorate certificate) or by
- "Zustimmung im Einzelfall" (exceptional approval)

This test report can underlie building supervisory procedures

for regular building products for the prescribed proofs of conformity

for non regular building products for the needed proofs of applicability.

This test report must not be published and copied without preceding agreement of the test laboratory and if agreed, only during validity and unchanged concerning appearance and contents.





1. Description of test material in condition as delivered

 PN 28924:
 "Tinos"
 Dessin: 8078
 colour: light grey (glossy)

 -fabric consisting of 100% Polyester FR side A: a little bit smoother surface

 characteristic values determined by the test laboratory:
 area weight: about 109 g/m²
 thickness: about 0,57 mm

The testing laboratory is not provided with further details concerning composition of the tested building materials. Samples are deposited.

2. Preparation of samples

The samples were kept in climate chamber 23/50 until they reached constant weight.

3. <u>Arrangement of samples</u> mounting: freely suspended

#2285	flaming side A in warp direction
#2286	flaming side B in warp direction
#2287	flaming side A in weft direction

4. Date of test CW 15 in 2019

5. <u>Results</u> The test has been examined according to DIN 4102 (Mai 1998)

	Measurement	Re	sult with the	ne tested s	pecime	ņ	Dim.
DO.	Test number	#2285	#2286	#2287			
line	flamed direction flamed side	warp A	warp B	weft A			
1	Number of specimen arrangement acc. to. DIN 4102/T15, schedule 1	1	1	1			
2 3	Maximum flame height above bottom edge of the specimen Time ¹⁾	30 0:02	30 0:02	30 0:02			cm min:s
4	Burn through / melting Time ¹⁾	0:03	0:02	0:03			min:s
5	Observations on the back side of the specimen Flames / Glowing Time ¹⁾ Change of color Time ¹⁾	.1. .1. .1. .1.	.J. .J. .J. .J.	.J. .J. .J. .J.	.1. .1. .1. .1.	./. ./. ./.	min:s min:s
7 8 9	Falling of burning droplets Start ¹⁾ <u>Extent</u> sporatic falling of burning droplets ²⁾ continuous falling of burning droplets ²⁾	.1. .1. .1. .1.	.I. .I. .I. .J.	./. ./. ./. ./.	.J. .J. .J.	.1. .1. .1. .1.	min:s
10 11 12	Falling of burning droplets Start ¹⁾ Extent sporatic falling of burning droplets ²⁾ continuous falling of burning droplets ²⁾	./. ./. ./.	.J. .J.	./. ./.	./. ./.	./. ./.	min:s
13	Afterflame time at the bottom of the sieve (max.)	./.	./.	./. ./.	./. ./.	.1.	min:s

P06-04-FB05 eng Rev01



Lerchenweg 1 D-97650 Fladungen

	Measurement	Re	esult with t	he tested s	pecime	n	Dim.
<u>e</u>	Test number	#2285	#2286	#2287			
line	flamed direction flamed side	warp A	warp B	weft A			
14	Impairment of the burner by dropping or falling material: Time ¹⁾	./.	./.	./.	.1.	./.	min:s
15 16	Premature end of test Final occurance of burning at the specimen ¹⁾	.1.	.1.	.1.	./.	./.	min:s
10	Time of eventually end of test ¹⁾		./.	./.	./.	./.	min:s
17 18 19 20 21	Afterflame after end of test Time ¹⁾ Number of specimen Front side of specimen ²⁾ Back side of specimen ²⁾ flame length	./. ./. ./. ./. ./.	.1. .1. .1. .1. .1.	./. ./. ./. ./.	.1. .1. .1. .1. .1.	./. ./. ./. ./. ./.	min:s cm
22 23 24 25 26 27	Afterglow after end of test Time ¹⁾ Number of specimen <u>Place of appearance</u> Lower half of the specimen ²⁾ Upper half of the specimen ²⁾ Front side of specimen ²⁾ Back side of specimen ²⁾	.I. .I. .I. .I. .I. .I. .I.	.I. .I. .I. .I. .I. .I. .I. .J.	.J. .J. .J. .J. .J. .J. .J. .J.	J. J. J. J. J. J. J. J.	.1. .1. .1. .1. .1. .1. .1. .1. .1.	min:s
28 29 30	<u>Density of smoke</u> ≤ 400 % * min > 400 % * min ⁴⁾ Diagram: encl. no.	1 ./. 1	1 ./. 2	1 ./. 3	 ./.	 ./.	% * min % * min
31	Residual lengths: individual value ³⁾ Specimen 1 Specimen 2 Specimen 3 Specimen 4	66	62 65 66 61	65 66 67 63			cm cm cm cm
32	Average value, individual test 3)	64	64	65			
33	Photo of specimen in enclosure no.	1	2	3			
34 35	Flue gas temperature Maximum of average value	119 09:51	119 09:57	122 10:00			°C min:s
36	Time ¹⁾ Diagram: encl. no.	1	2	3			11111.5
37	Remarks: - none -	1	2	5			L
57							

¹⁾ indication of times: from the begin of testing procedure
 ²⁾ checked off if applicable
 ³⁾ indication of carrier/foam layer separated in case of fire-proofing agents
 ⁴⁾ very strong development of smoke



6. Explanations concerning the testing procedure

There were no additional tests proceeded because of the residual length of \geq than 45 cm.

7. Summary of results and additional establishments to Fire Behaviour

linen o.	measurement	Result with the tested specimen							
line o	test-no.	#2285	#2286	#2287			dime		
	flamed direction flamed side	warp A	warp B	weft A					
1	residual length	64	64	65			cm		
2	max. smoke temperature	119	119	122			°C		
3	density of smoke - integral	1	1	1			%min		
4	remarks: none								

According to DIN 4102, part 1, "schwerentflammbare" (hardly flammable) building materials must meet the requirements of class B2.

Pursuant to additional tests in the ignitability apparatus this can be determined (appendix 4).

8. Special remarks

- This report is only valid for the material as described under paragraph 1. In combination with other materials or with additional coatings or grounds etc. the burning behaviour may differ.
- This test report is not valid for the exposure to outdoor climate conditions, washing or cleaning with chemicals.
- . This test report is not valid, as soon as the fabric is used as a building product in the sense of the "Landesbauordnungen" (state building requirements, MBO § 17, par. 3).
- This test report is no substitute for a General Building Inspectorate Certificate.
- This test report is granted without prejudice to the rights of third parties, im particular private proprietary rights.
- For legal interests only the German original version is relevant.
- In General Building Inspectorates procedures this test report can be based for
 - 0 regular building materials for the required proof of accordance
 - for not regular building materials for the required proof of applicability

9. Validity

This test report is valid until the mentioned date on page 1. The test report becomes invalid in case the standards on which the tests are based are changed.

USERNACHUNGS. Fladungen, 11.04.2019 PRÜF clerk in charge: Ш Fladunge (Dipl.-)ng.(FH) Jürgen Hammer)


Head of the test laboratory:

Dipl.-Ing.(FH) Andreas Hoch)

P06-04-FB05 eng Rev01




Prüfinstitut Hoch Lerchenweg 1 D-97650 Fladungen






Prüfinstitut Hoch Lerchenweg 1 D-97650 Fladungen









Test for normal flammability classifying B2 according to DIN 4102

- 1. Description of test material in condition as delivered look at page 2
- 2. Preparation of samples

Out of the material there have been cut samples for the ignitability apparatus. The samples were kept in a climate 23/50 until they reached constant weight.

3. Arrangement of samples -freely suspended-

Flaming in warp and weft direction / side A and side B

- 4. Date of test CW 13 in 2019
- 5. Results

"Tinos" Dessin: 8078: flaming side A in weft direction		sı	urfac	e-tes	t				edge	e-test	t		
samples no.	1	2	3	4	5	6	1	2	3	4	5	6	Dim
ignition ¹⁾	2	2	2	2	2		1						s
reaching the mark of measurement ¹⁾²⁾	-/-	-/-	-/-	-/-	-/-		-/-						s
max. flame height	4	4	4	5	5		3						cm
time	4	4	4	4	5		3						
self cessation of the flames end of afterflame ¹⁾	5	4	5	5	6		4						s
end of glowing ¹⁾	-/-	-/-	-/-	-/-	-/-		-/-						s
flames were extinguished after ¹⁾	-/-	-/-	-/-	-/-	-/-		-/-						
smoke development (visual)			very	little					very	little			./.
dropping of burning material during 20 s1)	-/-	-/-	-/-	-/-	-/-		-/-						s
Appearance after test: burned out till ma	ax. heiç	ght 9 c	cm x v	vidth 3	3 cm								
"Tinos": Dessin: 8078: additional tests		(edge	-test				s	urfac	e-te	st		
"Tinos": Dessin: 8078: additional tests samples no.	1	2	edge 3	-test 4	5	6	1	s 2	urfac 3	e-te : 4	st 5	6	Dim
	1				5	6	1				T	6	s Dim
samples no.	<u> </u>	2	3	4			<u>⊢ </u>	2	3	4	T		
samples no. ignition ¹⁾	1	2	3 1	4			2	2	3	4	T		s
samples no. ignition ¹⁾ reaching the mark of measurement ¹⁾²⁾ max. flame height time	1	2 1 -/-	3 1 -/-	4			2	2 2 -/-	3 2 -/-	4	5 		s s
samples no. ignition ¹⁾ reaching the mark of measurement ¹⁾²⁾ max. flame height	1 -/- 4	2 1 -/- 4	3 1 -/- 3	4			2 -/- 4	2 2 -/- 4	3 2 -/- 3	4	5		s s
samples no. ignition ¹⁾ reaching the mark of measurement ¹⁾²⁾ max. flame height time self cessation of the flames	1 -/- 4 3	2 1 -/- 4 3	3 1 -/- 3 3	4	 		2 -/- 4 5	2 2 -/- 4 5	3 2 -/- 3 3	4	5 		s s cm
samples no. ignition ¹⁾ reaching the mark of measurement ¹⁾²⁾ max. flame height time self cessation of the flames end of afterflame ¹⁾	1 -/- 4 3 4	2 1 -/- 4 3 4 -/- -/-	3 1 -/- 3 3 3 4 -/- -/-	4 	 		2 -/- 4 5 10	2 2 -/- 4 5 8	3 2 -/- 3 3 4 -/- -/-	4 	5 		s s cm s
samples no. ignition ¹⁾ reaching the mark of measurement ¹⁾²⁾ max. flame height time self cessation of the flames end of afterflame ¹⁾ end of glowing ¹⁾	1 -/- 4 3 4 -/-	2 1 -/- 4 3 4 -/- -/-	3 1 -/- 3 3 3 4 -/-	4 	 		2 -/- 4 5 10 -/-	2 2 -/- 4 5 8 -/-	3 2 -/- 3 3 4 -/- -/-	4	5 		s s cm s s
samples no. ignition ¹⁾ reaching the mark of measurement ¹⁾²⁾ max. flame height time self cessation of the flames end of afterflame ¹⁾ end of glowing ¹⁾ flames were extinguished after ¹⁾	1 -/- 4 3 4 -/-	2 1 -/- 4 3 4 -/- -/-	3 1 -/- 3 3 3 4 -/- -/-	4 	 		2 -/- 4 5 10 -/-	2 2 -/- 4 5 8 -/-	3 2 -/- 3 3 4 -/- -/-	4 	5 		s s cm s s

¹⁾ time mentioned from the beginning of the test²⁾ during 20 Sec -/- no appearance -- no information

6. Remarks and explanations to the testing procedure - none -

7. Opinion concerning the dropping of burning material

The test for normal flammability shows no burning dripping material.