



This document is the translation of the French certificate n° 16-01122 L on the 8th April, 2016 delivered by IFTH.

MATERIAL REACTION TO FIRE CLASSIFICATION REPORT

prepared in compliance with amended 5 of the French Home Office Regulation dated November 21st, 2002 (Official Gazette dated December 31, 2002)

Valid five years from issue date

CERTIFICATE N° 16-01122 L

And appendices of 6 pages

MATERIAL presented by :

VESCOM B.V
Sint Josefstraat 20
5753 AV DERUNE
NEEDERLAND

TRADE NAME :

DELOS

BRIEF DESCRIPTION :

Jacquard made from 100% inherent flame retardant polyester fibers.
Nominal surface weight : 266 g/m²
Measured thickness : about 0.6 mm
Colours : various

TEST REPORT :

N° 16-01122 _{E1-V1} on the 8th April, 2016

TESTS :

Electrical burner test
Flame persistence test
Dripping test.

CLASSIFICATION :

M 1

CLASSIFICATION DURATION (article 5 of appendix 2):

unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the 8th April, 2016

Head of Quality Management Test and trials
Jean-Marc ORAISON



ACCREDITATION
N° 1-0101 et
N° 1-0513
PORTÉE
COMMUNIQUÉE
SUR DEMANDE

ESSAIS