

**PROCES-VERBAL DE CLASSEMENT DE REACTION AU FEU  
D'UN MATERIAU PREVU A L'ARTICLE 5  
DE L'ARRÊTE DU 21 NOVEMBRE 2002**

Valable 5 ans à partir de la date de délivrance

V1-07-05-10

**PROCES-VERBAL N° MZC-10-1855M**

et annexes de 5 pages

**MATERIAU présenté par :** VESCOM BV  
St, Jozefstraat 20  
5753 AV Deurne - Nederland

**MARQUE COMMERCIALE :** TAVIRA

**DESCRIPTION SOMMAIRE :** Tissu pour rideaux occultants - 100% polyester FR ignifugé dans la masse

Masse surfacique nominale: 300g/m<sup>2</sup>  
Epaisseur nominale : 0,7 mm  
Coloris présentés : Divers

**RAPPORT D'ESSAI :** N° MZC-10-1855 du 16 juillet 2010

**NATURE DES ESSAIS :** Brûleur électrique  
Propagation de flamme  
Essai pour matériaux fusibles

**CLASSEMENT :**

**M1**

**DURABILITE du classement (article 5 de l'annexe 2) :** non limité à priori

Compte tenu des critères résultant des essais décrits dans le rapport d'essai annexé.

Ce procès-verbal atteste uniquement des caractéristiques de l'échantillon soumis aux essais et ne préjuge pas des caractéristiques de produits similaires. Il ne constitue donc pas une certification de produits au sens de l'article L.115-25 du code de la consommation et de la loi du 3 juin 1994.

Pour déclarer, ou non, la conformité à la spécification, il n'a pas été tenu explicitement compte de l'incertitude associée au résultat.

NOTA : Sont seules autorisées les reproductions intégrales et par photocopie du présent procès-verbal de classement ou de l'ensemble procès-verbal de classement et rapport d'essai annexé

**A Mazamet, le 16 juillet 2010**

Le Directeur ou son représentant

Richard RICO

Le responsable de l'étude

Sandrine PANIS




ACCREDITATION N°1-0513\*  
PORTEE DISPONIBLE  
SUR WWW.COFRAC.FR

**Direction Régionale Grand Ouest**

Boulevard du Thoré - 81200 AUSSILLON - MAZAMET

Tél. (33) 05 63 97 56 90 - Fax (33) 05 63 97 56 91

SIRET 433 430 832 00082



**MATERIAL REACTION TO FIRE CLASSIFICATION REPORT  
PROVIDED TO ARTICLE 5 OF THE FRENCH OFFICE  
REGULATION DATED NOVEMBER 21<sup>st</sup>, 2002**

Valid 5 years from the date of delivery

V1-07-05-10

**REPORT N° MZC-10-1855M**

and appendix of 5 pages

**MATERIAL presented by:** VESCOM BV  
St, Jozefstraat 20  
5753 AV Deurne - Nederland

**TRADE NAME :** TAVIRA

**BRIEF DESCRIPTION :** Fabric for blackout curtains - 100% polyester FR fireproofed in the mass  
Nominal surface density : 300 g/m<sup>2</sup>  
Nominal thickness : 0,7 mm  
Colors : various

**TEST REPORT :** N° MZC-10-1855 of July 16<sup>th</sup> 2010

**TESTS :** Electrical burner test  
Flame persistence test  
Dripping test

**CLASSIFICATION :** **M1**

**CLASSIFICATION DURATION (article 5 of appendix 2) :** unlimited otherwise specified

Given the criteria resulting from the tests described in the enclosed test report.  
The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.  
To declare, or not, the correspondence to the specification, it was not explicitly taken account the uncertainty associated with the result  
N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Mazamet, France, on July 16<sup>th</sup>, 2010

Director or empowered person

Richard RICO

Responsible for the test

Sandrine PANIS



ACCREDITATION N°1-0513\*  
PORTEE DISPONIBLE  
SUR WWW.COFRAC.FR

**Direction Régionale Grand Ouest**  
Boulevard du Thoré – 81200 AUSSILLON – MAZAMET  
Tél. (33) 05 63 97 56 90 – Fax (33) 05 63 97 56 91  
SIRET 433 430 832 00082