

## Application for approval of the trademark TREVIRA®

# Trevira

NO. 001445116 (2010), 15

Trevira GmbH  
Markenprüfung /  
Trademark Testing  
Technikum, Gebäude 515  
Max-Fischer-Straße 11  
D-86389 Bobingen

### Applicant

Company Vescom B.V.  
Road Sint Jozefstraat 20  
Post Code/City 5753 Deurne  
Country NL

Name / Signature *J.A. Schirmer*  
Schirmer

Trademark Trevira CS  
Article Coron  
End Use Drapes  
Other uses Bitte umschreiben  
Composition 100 % PES  
Fabric weight (g/sm) 184

### Yarn Details

Warp

Yarn titre/ count	Nm 450/1 CS		
Trevira Type	--		
Yarn supplier	Trevira		
	<b>Weft 1</b>	<b>Weft 2</b>	<b>Weft 3</b>
Yarn titre/ count	Nm 130/1 CS	Nm 60/2 CS	Nm 28/1 CS
Trevira Type	--	--	--
Yarn supplier	Lei Tsu/TFS/VLNP		

Approval: 08.09.2015

(This Trademark approval is valid for a period of 5 years from the date of issue).

The tested article CORON with application no. 151211 is granted approval for the trademark Trevira CS.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.

DIN EN ISO 6940/6941: No flaming ignition and no measurable spread of flame will occur with Trevira CS fabrics.

This article can meet the requirements according to ÖNORM A 3800-1 part 1, class B1, fume formation class Q 1 and droplet formation class TR1.

28.11.2016 i.A. B. Van Nieuwen

Trevira GmbH, Trademark Service