

Trevira
THE FIBRE COMPANY

Trevira GmbH
Markenprüfung /
Trademark Testing
Technikum, Gebäude 515
Max-Fischer-Straße 11
D-86399 Bobingen

**Application for approval of the trademark
TREVIRA®**

Applicant

Company Vescom B.V.
Road Sint Jozefstraat 20
Post Code/City 5753 Deurne
Country NL

Name / Signature *J.A. Schirmer*
Schirmer

Trademark Trevira CS
Article Syros
End Use Drapes
Other uses Bitte umschreiben
Composition 100 % PES
Fabric weight (g/sm) 230

Yarn Details

Warp

Yarn titre/ count	Nm 100/1 CS		
Trevira Type	--		
Yarn supplier	Lei Tsu		
	Weft 1	Weft 2	Weft 3
Yarn titre/ count	Nm 50/8 CS	Nm 70/2 CS	Nm 130/1 CS
Trevira Type	--	--	--
Yarn supplier	Padana/TGH/Lampertsmühle/Lei Tsu		

Approval: 29.05.2015

(This Trademark approval is valid for a period of 5 years from the date of issue).

The tested article SYROS with application no. 150690 is granted approval for the trademark Trevira CS. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.

NEN EN ISO 6940/6941: For Trevira CS fabrics no ignition and no rate of flame spread is measured.

This article can meet the requirements according to ÖNORM A 3800-1 part 1, class B1, fume formation class Q 1 and droplet formation class TR1.

26.02.2016 *Christl - Kays*

Trevira GmbH, Trademark Service