

## MATERIAL REACTION TO FIRE CLASSIFICATION REPORT

prepared in compliance with amended 5 of the French Home Office Regulation  
dated November 21<sup>st</sup>, 2002 (Official Gazette dated December 31, 2002)

Valid five years from issue date

**REPORT N° 13-04521 L**

And appendices of 7 pages

**MATERIAL presented by :** VESCOM B.V  
Sint Jozefstraat 20  
NL-5753 DEURNE

**TRADE NAME :** MINU-FARAY

**BRIEF DESCRIPTION :** Fabric made of inherent flame retardant polyester fibers TREVIRA CS  
Nominal surface weight : 223 à 251 g/m<sup>2</sup>  
Thickness : about 0.5 à 0.6 mm  
Colours : various

**TEST REPORT :** N° 13-04521 dated January 22<sup>th</sup>, 2014

**TESTS :** Electrical burner test  
Flame persistence test  
Dripping test.

**CLASSIFICATION :** **M 1**

**CLASSIFICATION DURATION (appendix 22):** unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on January 22<sup>th</sup>, 2014

Director or empowered person

**Bruno CHEVET**

PO 



ACCREDITATION  
N° 1-0101\*  
PORTÉE  
COMMUNIQUÉE  
SUR DEMANDE