



**TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.**  
(TEXTILE TESTING INSTITUTE)  
Václavská 237/6, 603 00 Brno, Czech Republic  
Certification body for the certification of products No. 3044  
accredited by CAI according to EN ISO/IEC 17065

issues



# CERTIFICATE

No. 19 – 029

Client: **Vescom B.V., Sint Jozefstraat 20, 5753 AV Deurne, Netherlands**  
ID: 17084508

Product: **Drapery**  
**- Formoza**

Material composition: 100 % Polyester FR  
Mass per unit area: 133 g.m<sup>-2</sup>

**This certificate shows the conformity of the product with the following technical specification:**

- **EN 13773:2003 Textiles and textile products - Burning behaviour - Curtains and drapes - Classification scheme**

Testing according to: **EN 1101:1995, EN 13772:2011**

**It is certified,**

**that assessed product meets the requirements of the technical standard EN 13773, class 1 regarding the burning behaviour.**

**The product does not ignite and does not burn in defined conditions.**

Certification system: Type testing (certification scheme No. 1 to EN ISO/IEC 17067).

This Certificate is issued within the scope of accreditation of Certification Body. The base for the Certificate is the Final Protocol No. COV/19/106 from 06. 05. 2019 issued by Certification Body Textile Testing Institute in Brno. Final Protocol is an inseparable part of the Certificate.

Certificate issued: Brno 07. 05. 2019

Validity up to: 31. 05. 2022



  
Ing. Svatava Horáčková  
Head of Certification Body