

Laboratory approved by the Ministry for the Interior
JO of February 10, 2007OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE
Of A MATERIAL ENVISAGED IN ARTICLE 5
DECREE OF November 21, 2002

Page 1

N° **CM - 19 - P - 078**

et 1 annexe de 4 pages.

Valid 5 years as from mardi 18 juin 2019

Material presents by : **VESCOM B.V**
Sint Jozefstraat 20
5753 AV DEURNETrade mark: **HESTAN**

Summary description

Kind of textile woven

Composition 100% polyester FR

Mass per unit area 570 g/ml (laize : 140 cm)

Tickness 1 mm (donnée laboratoire FCBA)

Color tous coloris

Nature of the test : Electrical burner test
Flame persistence
Dripping testClassification : **M1**

Observations : /

Durability of the classification (Article 5 de l'annexe 2) Not limited

Usual term Walls hung covering, sheers, curtains,...

Cleaning conditions Recommendation of Customer

Taking into account the criteria resulting from the tests annexed described in the test report N°FE 19-0211-0981

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"

Champs-sur-Marne, le mercredi 26 juin 2019

Technicienne d'essais
du Laboratoire Feu

Clotilde ETIEMVRE



Responsable Technique du Laboratoire

Feu

du Pôle Ameublement


Clémence RAWASSiège social
10 rue Galilée
77420 Champs-sur-Marne
Tél + 33 (0)1 72 84 97 84
www.fcba.fr
Siret 775 680 903 00132
APE 7219 Z
Code TVA CEE : FR 14 775 680 903Only the french version remains valide
Institut technologique FCBA : Forêt, Cellulose, Bois - construction, Ameublement